

MEBS6006 Environmental Services I (2007-2008)

SECTION A (Numerical Answers)

- A1. (a) Not applicable.
(b) i) Humidity ratio or moisture content:
 Initial = 0.0135 kg/kg ; final = 0.0101 kg/kg
 ii) Wet-bulb temperature: Initial = 21.2 °C ; final = 14.5 °C
 iii) Specific enthalpy: Initial = 61.5 kJ/kg ; final = 40.7 kJ/kg
 iv) Specific volume: Initial = 0.87 m³/kg ; final = 0.83 m³/kg
 v) The kW of refrigeration required = 41.3 kW
 The apparatus dew point = 13.8 °C
(c) Not applicable.
- A2. (a) Not applicable.
(b) i) Mixed air stream (m):
 - Dry-bulb temperature = 28.25 °C
 - Moisture content = 0.0131 kg/kg
 - Specific enthalpy = 63.6 kJ/kg
 ii) Air-conditioning process (s – r):
 - Sensible load = 24.5 kW
 - Latent load = 11.5 kW
 - Total load = 36 kW
 - Sensible heat ratio = 0.68
 iii) Ventilation load = 20.9 kW
 Supply system heat gain = 5.0 kW
 Return system heat gain = 4.6 kW
(c) Not applicable.
- A3. (a) Not applicable.
(b) i) Amount of the energy saving obtained from
 - “cooling” = 32,600 kWh; “lights” = 23,500 kWh
 ii) Density of the peak design cooling loads:
 - Reference case = 11.36 m²/kW; Low-energy case = 17.86 m²/kW
(c) Not applicable.

MEBS6006 Environmental Services I (2004-2005)

SECTION A (Numerical Answers)

- A1. (a) Not applicable.
(b) Not applicable.
(c) DBT = 26.05 °C; Moisture content = 12.2 g/kg; Dew point temp. = 17 °C
 Specific enthalpy = 57.2 kJ/kg
- A2. (a) Not applicable.
(b) Not applicable.
(c) Sensible heat ratio = 0.75
- A3. (a) Not applicable.
(b) Not applicable.
(c) Sensible heat ratio = 0.59; Design flow = 5.6 m³/s
 Energy utilization index = 176 kWh/m²/year; % of HVAC system = 48.9%